

Study and Analysis of Storage Tank Hazards and its Mitigation Measures Using Bow Tie Diagram

Vaibhav Sharma¹, Abhishek Nandan², Dr. Nihal Anwar Siddiqui³

M. Tech (HSE), Department of Health,
Safety & Environment, University of Petroleum & Energy Studies, Dehradun (Uttarakhand) INDIA

Abstract: Petroleum and petrochemical industry may lead to hazard condition by means of fire, explosion, explosive chemical noise, electrical shock and etc. which result in health, environment and economic loss. These hazards can be a result of the presence of cleaning chemicals, hazardous gases, improper or insufficient lockout-tag out, vapors, fumes, dusts, or excessive heat or cold. Atmospheric storage tank fire very common in industrial facilities. In this work various accidents of storage tanks that taken place in Industrial facilities in Asia over last 40 years. Bowtie Diagram is applied to depict causes and factors responsible which led to various types of storage tank fires. Prevention and mitigation measures are also provided to help operating engineers handling similar types of situations in the future. The results show that 70% of accidents occurred in oil terminals or storage, petroleum refineries and Fire and explosion account for 90% of the accidents. There were accidents caused by lightning, by human errors, including poor operations and maintenance. Other causes were equipment failure, static electricity, sabotage, crack and rupture, leak and line rupture, open flames, etc. Most of these accidents would have been avoided if proper safety management programs, good engineering practices implemented.

Keywords: Good Engineering practices, Fire, and Explosion, Safety Management Program, Bowtie Diagram.

1. Introduction

Flammable and combustible liquid storage tanks are found in refineries, petrochemical plants, bulk storage of petroleum products and marine terminals. Airports, local fuel companies, power plants and large manufacturing facilities such as automobiles and steel plants may also have bulk storage of flammable and combustible liquids (Hildebrand and Noll 2017).

Storage tanks store flammable and combustible liquids in various ways, depending on the facilities. These tanks can vary from 5 meters to 150 meters in diameter and can have an average height of 15 meters. These flammable liquids such as heavy oil, petrol, diesel, kerosene, ATF, etc. are stored in tanks at atmospheric temperature or under low pressure of 0.5 bar (Lahiri 2017). If they found sufficient amount of energy, they may get ignite and can lead to fire or explosion. If an explosion occurs it may have a devastating effect with waves or overpressure created during explosion, which affects nearby tank also and can be a catastrophic situation. Such tanks can store huge volume of crude and other petroleum products of flammable and combustible liquids. Larger industrial facilities may own more than 300 Tanks of varying sizes which contain various products. These tanks may be placed very near to each other and have several other tanks within a common dyke.

The storage tank is covered by the peripheral boundary called dykes which acts as barriers to prevent the spilled liquid due to overflow or structural failure of the tank. Every tank is separated and segregated according to their classification. They are usually made of compacted dirt or concrete similar type materials. The dyke of height is considered 2m. It can be extended on the special recommendation to prevent overflow of flammable liquids. Dykes are made consideration of the total capacity of the tank and additional certain percentage above this as a safety margin. If there is more than one tank in one dyke, the dyke capacity should be at least the volume of the largest tank in consideration a safety margin (Directorate 2007).

2. The types of tanks are:

1. Fixed roof tanks
2. Internal floating roof
3. Open top floating roof tanks

2.1 Fixed Roof Tanks

Tanks with fixed roofs include cone roof tanks, dome roof tanks, and column supported roof tanks, all of which are of either welded, riveted (other types), or bolted (other types) construction. Fixed roof tanks are typically used to store a range of refined products, from volatile materials to heavy fuel oils.




Fig. 2.1 Fixed Roof Tank

Fixed roof tanks (Fig. 2.1) are welded to the curb at the top of the shell and covered from top section and shell is formed in such a way that the forces are resisting downwards, such as dome roof and conical shape. The tanks have one or more structural section called wind girders which are placed around the tank from the top for resisting bulking and wind loads. The minimum thickness of the roof plating is 5 mm on the new tank. The minimum thickness of the roof plating is 5 mm of a new tank. To support the roof plating in tanks up to about 30 meters diameter(McGrath 1963).

Roof trusses often extend downwards below the curb and therefore may lead to a reduction in storage capacity if, at a later stage. The fixed roof tank is made to hold an internal floating roof cover. The roof plating is attached to the curb, by welding, and if specified the weld may be minimal to make the joint frangible as a protection against accidental overpressure.

All fixed roof should be vented by open vents or through pressure/vacuum valves. For liquids to get in, air and vapor must be pushed out. The pressure in the tank must be slightly above atmospheric.

For a liquid to get out, air and vapor must be sucked in for this the pressure in the tank must be slightly below atmospheric. (Fig. 2.2)




Fig. 2.2

Dome roof tanks are similar to internal floating roof tanks are designed as a cover over the external floating roof tank. The main purpose of dome roof is to provide protection from fugitive emission to the environment.

2.2 Internal Floating Roof Tank

Internal floating roof tank (Fig. 2.3) consists of a permanently fixed roof with a floating roof inside the tank. The internal roof floats on pontoons or has a double deck for floatation over the liquid surface. These tanks will generally be found in service conditions where high volatility (Low Flash Point) or toxic liquids are stored. In a fixed roof tank without a floating cover, the liquid surface is in direct contact with the airspace above it.

The presence of an internal floating cover reduces these vapor losses by at least 95%, a very important feature where high cost, toxic or flammable materials are concerned. The tank will normally be fitted with open vents around the fixed roof (as Specified in BS 2654 and API 650), but PV vents are often used in practice.




Fig. 2.3 Internal Floating roof Tank.

2.3 External Floating Roof Tank

External floating roof tank consists of a roof which floats on the surface of the liquid, but the roof is exposed to the atmosphere. The roof goes up and down with the change in liquid level. The external floating roof consists of rim seal which prevents the vapors from escaping. Typically, such tanks are used for the storage of crude oil and all volatile (low flash point) products. Crude oil tends to be self-protective where the open tank shell is concerned, while white oils lack this property and the exposed shells become roughened by exposure to the weather.




Fig. 2.4 External Floating Roof Tank

3. Causes of Accidents

1. Lightning

Lightning is one of the most common sources of ignition that may lead to a fire on atmospheric floating roof tanks. In a survey 95% of fire events taken place with the lightning-ignited rim seal fires (Mansour 2012). It is not necessary that lightning should directly strike on a tank for ignition to occur, a strike in the immediate nearby can generate that certain amount of static charge between the tank shell and floating roof tank that may lead to a fire. The Recent fire which took place on Diesel tank, due to thunder stormed noticed on Butcher Island off Mumbai in Oct 2017 since no fatality was noticed but It took four hours for fuel to completely burn off. This incident costs a nearly financial loss of at least 60-70 crore. Another fire which took place on crude oil tank at HPCL in July 2017 due to the lightning strike at Vishakhapatnam (Behera and Hassan 2017).

2. Maintenance error

Welding, Grinding during maintenance work is responsible for some catastrophic failures of storage tank vapor explode. Electric sparks and shocks can ignite flammable liquids or vapors lead to fire or explosion also. An incident caused at Lanjou, china refinery due to electric shock generated from electric motors and an incident in 1984 at Kaohsiung, Taiwan has resulted in the same cause (Qingxiang 1999). A chemical plant at Chaiyi, an accident caused by sparks generated from the electric soldering machine. To minimize electric hazards, each section, rooms, and areas must be taken into account in determining its classification defined in NFPA 70, National Electrical Code, Article 500, Hazards (Classified) Locations (Keller 2010).

3. Operational error

Overfilling of tanks is about the frequent cause of this category. Products came out releasing large volumes of vapors into the atmosphere and finding some ignition source lead to fire or explosion. If the tank is filled with flammable liquid and if it overfills, fire or explosion is almost nonavoidable. In 2001, Wuyi, Zhejiang, China, 50 Kg of Benzene leaked due to overfilling of tank leads to 46 Children and 2 villagers hospitalized (Chang and Lin 2006).

Eight out of Ten accidents take place in leakage due to Operational Error. In 2009, Jaipur fire at Indian Oil Corporation, Terminal, is caused due nonavailability of Standard procedure and Absence of Leakage stop device from a remote location i.e remote operated valve (Gupta 2010).

4. Sabotage

Sabotage is the fourth cause which can have an impact on any incident on the storage tank. Any terrorist activity or theft operation can lead to major emergencies. The Serval tank farm was put on fire during the Iraqi occupation of Kuwait in 1991. Few burnt tanks were fought for Extinguishment, the rest was left for complete burnout due to the war situation (Ghabra 1991).

5. Equipment failure

An external floating roof tank of the tank consists of roof drain, breather Valve, and emergency roof drain. There were cases where roof drain found chocked and water gets accumulated on the surface of roof resulting in rook sunken case. Sometimes the excess pressure develops inside the, to relive breather valve is provided, it is found that valve failure leads to buckling of the tank. There is a seal, which is provided on the perimeter of the tank which slides up and down with the tank roof and protects the vapor from escaping out. Failure of seal or material integrity loss leads to Serval incidents of vapor escape (Hellemans 2009).

6. Static electricity

Taking samples of storage tanks containing flammable liquids in open area results in static electricity. An accident in Japan in 1992 used metal devices or container for taking sample connected with conductive threads (Chang and Lin 2006). To minimize the hazard, avoid taking a sample in open access. If the open access sample is unavoidable, better use nonconductive materials sampling gauges. Avoid using any device made of metal. The maximum static charge is developed during transferring of material. Bonding of containers should be done to make potential equal.

7. Leak and line rupture

The incident took place in 1977, there is LPG leaked at Vishakhapatnam for without detected for Serval hours and after tanker ship pumped at the shore of Vishakhapatnam, resulting in a thick blanket of smoke which overwhelming the entire port city resulting in 37 deaths and 100 injuries (Arefi and Meyers 2003).

8. Open flames

Open Flames resulting from cigarette smoking, ground fires, and hot particles also ignite flammable vapors around storage tanks.

9. Natural disasters

Due to Impact of seismic motions in earthquake phenomenon on the structure of storage tank leads to cracking of its structure which leads to leakage of flammable liquid due to a disturbance in equilibrium. As Asia comes in an earthquake-prone area, there is always a fear of some catastrophic failure of a tank. Fortunately, there are only a few cases which result from an earthquake. The fire involved in Japan Refinery in 1964 in Niigata, resulted from sparks ignited hydrocarbon vapors released due to an earthquake (Moshashaei, Alizadeh et al. 2017).

10. Runaway reactions

Runaway reaction may take place when impurities mixed with material stored in tanks resulting in an Exothermic reaction. One of biggest disaster that took place in India, Bhopal gas Tragedy, 1984, caused due to water got mixed with methyl isocyanate stored in underground storage tank releasing huge volume of toxic gas killing hundreds of people (Broughton 2005).

4. Types of Incident scenarios and their Mitigation Measures.

1. **Boil Over:** - Boil over is a phenomenon which occurs in storage tank fire consist of heavy hydrocarbon or a blend of hydrocarbon liquids eg. Crude is released in explosive form when burning oil comes in contact with water, which settled at bottom of the tank. The heat is dissipated downwards and converts water into steam which expands 1500 times and carries burning crude with it. A boil over in tank covers an area of approximately 10D of the tank in Downwind direction and 5D of the tank in crosswind directions (Crippa, Fiorentini et al. 2009).

Crude Tank has following characteristics:

- Crude contains roughly 5% water
- Water layer at tank bottom +/- 1.5 meter
- Heatwave grows with +/- 0.6 meter/hr.
- Temperature of heat wave between 150 and 300 degree Celsius
- Burning rate of crude oil 15 cm/hr.

2. **Slopovert:** - Slopovert is a phenomenon which occurs when water is applied to full surface fire tank and the water gets accumulated downwards results in overflow of product from the tank.

3. **Vent Fire:** - Vent fire takes place in the fixed roof tank when one or more of vents gets ignited due to vapor flammable vapor released. The presence of flammable vapors has been always there either due to tank filling operation or tank's daily breathing cycle. More of vent fire found due to lightning strikes or found some ignition source nearby.

4. **Full Surface fire (Fixed roof Tank):** - A full surface of the fixed roof can occur due to vent fire escalation. A vapor cloud explosion can occur if flammable vapor is found within flammable range during the flame flashback, mainly if flame arrestors/PV are not in working condition. If a tank is constructed as per API 650, it should separate from weal seam. Depending on the vapor space explosion force, the roof may remove partially ("Fish's mouth" opening) or fully removed.

5. **Full Surface Fire (Open Floating roof tank.):** - Full surface fire is one where the tank roof has lost its buoyancy and some or the entire liquid surface has been exposed and involved in fire.

Causes

It causes due to rain build up on the roof, where there is inadequate drainage either from plugging of the drains or the rain amount received exceeds the design standards for the tank.

Measures

- Reduce inventory and allows to burn down

- Protect adjacent tanks
- Prepare for foam attract
- Estimate boil over time and prepare
- Avoid working in bund
- Position finding for placement of attack monitors

6. **Rim Seal Fire:-** A rim seal fire takes place where the seal between the tank shell and roof has lost its integrity and released vapors exposed to an ignition source and involved in fire.

Causes

Almost 95% of rim seal fire causes are due to lightning strikes. Hot work on roof is one of the few causes of rim seal fire.

Measures

- During an exceptional situation you can use small team to extinguish fire.
- Following are few measures to manage rim seal fire.
- Identify an extent of fire
- Open drain valve of tank rook
- Used fixed foam system
- Use portable foam hand lines from wind girders.

7. **Bund Fire:-** A fire in the band is a type that occurs outside the tank shell within the containment area. These types of fire involved small spillage fill up to fire covering whole bund area.

Causes

- Spillage and consequently ignition in bund area
- Leakage from mixers/inlet flange.

Measures

- Identify an extent of fire (Incase of leakage, Identify source of leakage and possibility of isolation)
- Use portable foam hand lines from wind girders.

8. **Spill On Roof fire:-** A spill on roof fire is a fire in a liquid of limited depth on a roof that still maintains its buoyancy.

Causes:

- It can result from a number of different hydrocarbon releases and ignition events.
- Crack in the skin of the roof
- If the tank loses buoyancy and partially sinks
- Flammable vapors escaping through a tank vent or roof fitting.

Measures

- Identify an extent of fire
- Use portable foam hand lines from wind girders.

5. Methodology

The major tank accidents that had been occurring in Asia in last few decades has been reviewed in this paperwork. The data are collected from various published reports. It has been found the major accidents have taken place in Oil & Gas sector as compared to a petrochemical plant, storage terminals and other facilities like gas plants, power plants, and fertilizer industry. This work explains with the help of a Bow Tie diagram (Fig. 5.1) using BowTie XP Software for different causes of events that is explained above which was responsible for incidents happened that lead to the different fire scenarios as worse case which can be prevented if proper mitigation measures have been taken into account or proper SOPs and SMPs is followed.

Various Preventive barriers have been taken into account with different threats and proactive/recovery barriers or mitigation measures with consequences with escalation factors for both threats and consequences.




Fig. 5.1 Bowtie Diagram

6. Result and Discussion.

This section covers Causes and consequences of storage tank hazards with their mitigation measures. Various preventive barriers which related to the particular threat through bow-tie diagram has been identified and expressed which also includes its escalation factors that have acted as an additive to hazards. After identifying all types of threats such as equipment failure, lightning, operational factors, etc., the consequence has been described with their mitigation measures such Automatic deluge system, Portable foam monitors application, Product pump out etc. which have decreased the effect of consequence that has taken place.

As there is mitigation measure which act as proactive /recovery barriers also have an escalation factor of consequence that have put a stop or act as a hurdle in extinguishment or reducing the consequence, such as inadequate supply of foam which is a hurdle for application of foam monitors or chocking of nozzle for automatic deluge system etc.

It has been found that if proper maintenance of these equipment's, better and efficient equipment is used this can prevent the escalation factors for consequences.

Conclusion

In this paperwork accident taken place in industrial facilities on various tanks has been reviewed. The Cause and factor responsible that led to catastrophic consequences were expressed with the help of a Bowtie diagram in a systematic way. Most of the accidents would have avoided if maintenance and operation, good engineering in design, construction has been practiced and proper safety management programs, SOPs, SMPs implemented and executed.

References

- [1] Arefi, M. and W. R. Meyers (2003). "What is public about public space: The case of Visakhapatnam, India." *Cities* **20**(5): 331-339.
- [2] Behera, R. K. and M. I. Hassan (2017). "Disaster Management using Mock Drills." *Vilakshan: The XIMB Journal of Management* **14**(1).
- [3] Broughton, E. (2005). "The Bhopal disaster and its aftermath: a review." *Environmental Health* **4**(1): 6.
- [4] Chang, J. I. and C.-C. Lin (2006). "A study of storage tank accidents." *Journal of loss prevention in the process industries* **19**(1): 51-59.
- [5] Crippa, C., et al. (2009). "Fire risk management system for safe operation of large atmospheric storage tanks." *Journal of loss prevention in the process industries* **22**(5): 574-581.
- [6] Directorate, O. I. S. (2007). "Fire protection facilities for petroleum refineries and oil/gas processing plants." Committee for Fire Protection, New Delhi, India.
- [7] Ghabra, S. (1991). "The Iraqi Occupation of Kuwait: An Eyewitness Account." *Journal of Palestine Studies* **20**(2): 112-125.
- [8] Gupta, K. (2010). "Design of district emergency operations centres, and the case study of Indian Oil Corporation Jaipur depot explosion." *International Journal of Emergency Management* **7**(3-4): 221-232.
- [9] Hellemans, M. (2009). *The safety relief valve handbook: design and use of process safety valves to ASME and international codes and standards*, Elsevier.
- [10] Hildebrand, M. S. and G. G. Noll (2017). *Above Ground Bulk Storage Tank Emergencies*, Jones & Bartlett Learning.
- [11] Keller, K. (2010). *Electrical Safety Code Manual: A Plain Language Guide to National Electrical Code, OSHA and NFPA 70E*, Butterworth-Heinemann.
- [12] Lahiri, A. K. (2017). *Material Selection and Performance in Oil and Gas Industry. Applied Metallurgy and Corrosion Control*, Springer: 269-347.
- [13] Mansour, K. A. (2012). *Fires in large atmospheric storage tanks and their effect on adjacent tanks*, © Khalid Mansour.
- [14] McGrath, R. V. (1963). "Stability of API standard 650 tank shells." *Proceedings of the American Petroleum Institute, Section III—Refining*, American Petroleum Institute, New York **43**: 458-469.
- [15] Moshashaei, P., et al. (2017). "Investigate the Causes of Fires and Explosions at External Floating Roof Tanks: A Comprehensive Literature Review." *Journal of Failure Analysis and Prevention* **17**(5): 1044-1052.
- [16] Qingxiang, L. M. L. (1999). "Major Safety Problems and Their Countermeasures in the Design of Large Size Petroleum Storage Tanks [J]." *CHINA SAFETY SCIENCE JOURNAL* **5**: 012.